

NOARK



Residual Current Circuit Breaker Ex9L-N 4P 40A A 100mA

Stamps

CE

RoHS



Especificación técnica

Brand	NOARK	Rated fault current [A]	0.1
IP	20	Leakage current type	A
EAN Code	8592765083661	Selective protection	No
Operating Frequency	50Hz	Short-circuit breaking capacity (I_{cn}) [kA]	6
Mounting method	DIN rail	Surge current capacity [kA]	3
Width in number of modular spacings	4	Additional equipment possible	No
Power loss [W]	15.3	Construction size (in accordance with DIN 43880)	4
Number of poles (total)	4	Built-in depth [mm]	79
Nominal rated voltage [V]	400	Short-time delayed tripping	No
Nominal rated current [A]	40	Warranty	5 Years