

EU Type Examination Certificate Number: 0120/SGS0142

Zhejiang Eastron Electronic Co., Ltd.

No. 1369, Chengnan Road, Jiaxing, Zhejiang, China, 314001

Instrument Identification:

SDM 630M CT Series

Polyphase, Active Import/ Export kWh, Indoor, Multi-Function, Transformer Operated, Electricity Meter

Instrument Traceable Number 0120/SGS0142

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted, it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

This certificate is valid until 9th March 2024 Issue 1

Certification is based on report number(s) EMA174647/1/MID dated 30th January 2014 EMA174647/1/MID/iss 2 dated 9th October 2019 EMA281302/1 dated 14th January 2022

Authorised Signature

Tuomas Hänninen

SGS Fimko OY, Notified Body 0598 Takomotie 8, FI-00380 Helsinki, Finland t +358 9 6963 61 www.sgs.fi





0120/SGS0142

Issue Number: 1

Dated:21st January 2022

1. Technical Data

Manufacturer	urer Zhejiang Eastron Electronic Co., Ltd.		
Meter Type	SDM630M CT V1, SDM630M CT V2, SDM630M CT-Mbus V2, SDM630M CT-2T V2, SDM630MCT-E, SDM630MCT-DI, SDM630MCT-2T-Mbus, SDM630MCT-MT, SDM630MCT-LoRa		
Voltage Rating (Un)	3x230/400V		
Current Rating (Imin - Iref (Imax))	0.05-5(6)A		
Frequency (Fn)	INDEXESSION DESCRIPTION OF THE PROPERTY OF THE		
Active Accuracy Class (kWh)	B or C (kWh)		
Type of circuit	3p4w, 3p3w, 1p2w		
Temperature Range	-40°C to +70°C		
Software/ Firmware Version No's Sessessessessessessessessessessessessess	SDM630M CT: V1.3 SDM630M CT-2T: V1.4 SDM630M CT-Mbus: V1.5 SDM630MCT-E: V1.6 SDM630MCT-DI: V1.8 SDM630MCT-2T-Mbus: V1.9 SDM630MCT-MT: V1.7 SDM630MCT-LoRa: V3.4 SDM630MCT: 0x0000D5C8 SDM630MCT-2T: 0x0000D279 SDM630MCT-Mbus: 0x00001516 SDM630MCT-E: 0x000080FA SDM630MCT-Di: 0x005D2CB2 SDM630MCT-T-Mbus: 0x0000147B SDM630MCT-MT: 0x00597DE9 SDM630MCT-LoRa: 0x7227CB		
Identification Location	\(\subsection \) \(\sub		
Bill Of Materials No's	SDM630MCT V1: SDM630-1 V1.5 SDM630MCT V2: DH-JS-150046-1.4 SDM630MCT-Mbus V2: DH-JS-160008-1.4 SDM630MCT-2T V2: DH-JS-160004-1.4 SDM630MCT-E: DH-JS-150046-1.4 SDM630MCT-DI: DH-JS-190005-1.0 SDM630CT-2T-Mbus: DH-JS-190019-V1.1 SDM630MCT-MT: DH-JS-190004-V1.1 SDM630MCT-LORa: DH-JS-200013-V1.0		
IP Rating	IP51		
Insulation Protective Class	Class II		
LED Pulse Constant	3200imp/ kWh		
Impulse Voltage Rating	6kV		
AC Voltage Rating	4kV		
Main Cover Sealing Type	2 x Wire & Crimp		



0120/SGS0142

Issue Number: 1

Dated:21st January 2022

Integrity of meter	\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6	Inaccessible without breaking seals
Intended Location of the Meter	3656262626262626262626262626262626262626	444446955555555555555555555555555555 185655555555555555555555555555555555555
Type of Register	SGSGSGSGSGSGSGSGSGSGSGSGSGSGSGSGSGSGSG	MARIAN DE SES CINCARDO PRODUCTION DE CONTRACTOR DE CONTRAC
Terminal Arrangement(s)	0.000000000000000000000000000000000000	UNBSSSD0099000018 IS GERG GEGGGC GERG GERG GERG GERG GERG GE
Location of Manufacturers Address	365656565656565656565656565656565656565	Side of meter




0120/SGS0142

Issue Number: 1

Dated:21st January 2022

2. Photograph of Meter and Sealing Plan







0120/SGS0142

Issue Number: 1

Dated:21st January 2022

3. Examples of Nameplates





Three Phase Energy Meter 3x230/400V AC 0,05-5(6)A 50Hz IP51 2022

3x230/400V AC 0,05-5(6)A 50Hz IP51 2022 3200imp/kWh EN50470-1/3 SW:1.3 CAT III

Manufactured by Zhejiang Eastron Electronic Co., Ltd.
No. 1369, Chengnan Rd. Jiaxing, Zhejiang, China

EASTRON

SDM630MCT V2 0120/SGS0142 Three Phase Energy Meter 3x230/400V AC 0,05-5(6)A 50Hz IP51 2022

Manufactured by Zhejiang Eastron Electronic Co., Ltd. No.1369. Chengnan Rd. Jiaxing, Zhejiang, China



EASTRON

SDM630MCT-MT V2 0120/SGS0142 Three Phase Energy Meter 3x230/400V AC 0,05-5(6)A 50Hz IP51 2022 3200imp/kWh EN50470-1/3 SW:1.7 CAT III

Manufactured by Zheijiang Eastron Electronic Co.,Ltd.
No.1369.Chengnan Rd. Jiaxing, Zheijiang, China

EASTRON

SDM630MCT-MT V2 0120/SGS0142 Three Phase Energy Meter 3x230/400V AC 0,05-5(6)A 50Hz IP51 2022 3200imp/kWh EN50470-1/3 SW:1.7 CAT III





EASTRON

SDM630MCT-Mbus V2 0120/SGS0142 Three Phase Energy Meter

3x230/400V AC 0,05-5(6)A 50Hz IP51 2022 3200imp/kWh EN50470-1/3 SW:1.5 CAT III

Manufactured by Zhejiang Eastron Electronic Co..Ltd.
No.1369.Chengnan Rd. Jiaxing, Zhejiang, China

E EASTRON

SDM630MCT-Mbus V2 0120/SGS0142 Three Phase Energy Meter

3x230/400V AC 0,05-5(6)A 50Hz IP51 2022 3200imp/kWh EN50470-1/3 SW:1.5 CAT III



Manufactured by Zhejiang Eastron Electronic Co.,Ltd. No.1369.Chengnan Rd. Jiaxing, Zhejiang, China



EASTRON

SDM630MCT-2T V2 0120/SGS0142 Three Phase Energy Meter

3x230/400V AC 0,05-5(6)A 50Hz IP51 2022 3200imp/kWh EN50470-1/3 SW:1.4 CAT III

(€M22 8 © □ \ A 3K6

Manufactured by Zhejiang Eastron Electronic Co.,Ltd. No.1369,Chengnan Rd. Jiaxing, Zhejiang, China

E EASTRON

SDM630MCT-2T V2 0120/SGS0142 Three Phase Energy Meter

3x230/400V AC 0,05-5(6)A 50Hz IP51 2022 3200imp/kWh EN50470-1/3 SW:1.4 CAT III

Manufactured by Zhejiang Eastron Electronic Co., Ltd. No. 1369. Chengnan Rd. Jiaxing, Zhejiang, China



0120/SGS0142

Issue Number: 1

Dated:21st January 2022









E EASTRON

SDM630MCT-2T-Mbus 0120/SGS0142 Three Phase Energy Meter

3x230/400V AC 0,05-5(6)A 50Hz IP51 2022 3200imp/kWh EN50470-1/3 SW:1.9 CAT III

C €M22 🖁 © 🗆 😭 🛦 3K6

Manufactured by Zhejiang Eastron Electronic Co.,Ltd No.1369.Chengnan Rd. Jiaxing, Zhejiang, China

EASTRON

SDM630MCT-2T-Mbus 0120/SGS0142 Three Phase Energy Meter 3x230/400VAC 0,05-5(6)A 50Hz IP51 2022

3200imp/kWh EN50470-1/3 SW:1.9 CAT III C €M22 🖁 © 🗆 🕆 🛆 3K7

Manufactured by Zhejiang Eastron Electronic Co.,Ltd No.1369.Chengnan Rd. Jiaxing, Zhejiang, China

₱ EASTRON

SDM630MCT-DIV2 0120/SGS0142 Three Phase Energy Meter

3x230/400V AC 0,05-5(6)A 50Hz IP51 2022 3200imp/kWh EN50470-1/3 SW:1.8 CAT III

Manufactured by Zhejiang Eastron Electronic Co., Ltd. No. 1369. Chengnan Rd. Jiaxing, Zhejiang, China

E EASTRON

SDM630MCT-DIV2 0120/SGS0142 Three Phase Energy Meter

3x230/400V AC 0,05-5(6)A 50Hz IP51 2022 3200imp/kWh EN50470-1/3 SW:1.8 CAT III

(€M22 🖁 © 🗆 😭 🐧 3K6 Manufactured by Zhejiang Eastron Electronic Co., Ltd. No. 1369. Chengnan Rd. Jiaxing, Zhejiang, China

E EASTRON

SDM630MCT-E V2 0120/SGS0142 Three Phase Energy Meter 3x230/400V AC 0,05-5(6)A 50Hz IP51 2022 3200imp/kWh EN50470-1/3 SW:1.6 CAT III

C €M22 🖁 © 🗆 😭 🛆 3K6 Manufactured by Zhejiang Eastron Electronic Co., Ltd. No. 1369. Chengnan Rd. Jiaxing, Zhejiang, China

E EASTRON

SDM630MCT-E V2 0120/SGS0142 Three Phase Energy Meter 3x230/400V AC 0,05-5(6)A 50Hz IP51 2022 3200imp/kWh EN50470-1/3 SW:1.6 CAT III

C €M22 🖁 © 🗆 😭 🛦 3K7 Manufactured by Zhejiang Eastron Electronic Co., Ltd. No. 1369. Chengnan Rd. Jiaxing, Zhejiang, China

EASTRON

SDM630MCT-LoRa 0120/SGS0142 Three Phase Energy Meter 1Ф2W, 1Ф3W, 3Ф3W, 3Ф4W 3x230/400VAC 0.25-5(6)A 50Hz SW V3.4 3200imp/kWh EN50470-1/3 Cl.B CAT III Y2022

(€M22 🖁 ® □ 🛕 3K6 IP51 Manufactured by Zhejiang Eastron Electronic Co., Ltd. No. 1369. Chengnan Rd. Jiaxing, Zhejiang, China

EASTRON

SDM630MCT-LoRa 0120/SGS0142 Three Phase Energy Meter 1Ф2W, 1Ф3W, 3Ф3W, 3Ф4W 3x230/400VAC 0.25-5(6)A 50Hz SW V3.4 3200imp/kWh EN50470-1/3 Cl.B CAT III Y2022

(€M22 🖁 ® □ 🛕 3K7 IP51

Manufactured by Zhejiang Eastron Electronic Co., Ltd. No. 1369. Chengnan Rd. Jiaxing, Zhejiang, China



0120/SGS0142

Issue Number: 1

Dated:21st January 2022

4. Calculation of the composite error/ MPE

During the type approval examination the influence factors for temperature, frequency and voltage are determined per load point. The table below represents the sum of the square values per load, determined via the following formula:-

$$\delta e(T, U, f) = \sqrt{(\delta e^2(T, I, \cos\varphi), \delta e^2(U, I, \cos\varphi), \delta e^2(f, I, \cos\varphi))}$$

Where

 $\delta e(T, I, \cos \varphi) = Additional error due to variation of the temperature at the same load <math>\delta e(U, I, \cos \varphi) = Additional error due to variation of the voltage at the same load <math>\delta e(f, I, \cos \varphi) = Additional error due to variation of the frequency at the same load$



0120/SGS0142

Issue Number: 1

Dated:21st January 2022

		Influence Factors for temperature, frequency and voltage							
Current	PF Cos	-40°C	-25°C	-10°C	5°C	30°C	40°C	55°C	70°C
lmin	1.0	1.01	0.85	0.50	0.07	0.12	0.13	0.15	0.11
ltr	1.0	1.07	0.91	0.54	0.25	0.10	0.14	0.16	0.12
10ltr	1.0	1.18	0.85	0.50	0.23	0.03	0.09	0.12	0.14
Imax	1.0	1.19	0.86	0.51	0.24	0.05	0.08	0.12	0.16
ltr	0.5ind	1.34	1.08	0.70	0.37	0.16	0.16	0.17	0.33
10ltr	0.5ind	1.15	0.79	0.43	0.17	0.09	0.13	0.18	0.16
Imax	0.5ind	1.17	0.79	0.43	0.18	0.10	0.15	0.17	0.21
ltr	0.8cap	1.12	0.85	0.48	0.21	0.06	0.10	0.15	0.12
10ltr	0.8cap	1.14	0.87	0.51	0.24	0.02	0.06	0.11	0.13
Imax	0.8cap	1.16,56565 656565656565656565656565 65656565	0.89	0.51	0.26	0.03	0.06	0.10	0.14
L1	SSGSGS	8020202 8020202 802020202020202020202020	\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6\$6	6503656365656565656565656565656565656565	GSGSGSGSGSGSGSGSGSGSGSGSGSGSGSGSGSGSGS	6363636363636363636 6363636363636363636	\$6\$69656565 \$6\$6965656565 \$6\$6\$6565656565 \$6\$6\$6565656565		
ltr	1.0	1.26	0.92	0.38	0.20	0.11	0.13	0.13	0.15
10ltr	1.0	1.17 GSGSGS	0.85	0.48	0.22	0.05	0.12	0.17	0.17
Imax	1.0	1.19	0.87	0.50	0.24	0.05	0.10	0.16	0.13
ltr	0.5ind	1.01	0.90	0.48	0.17	0.31	0.21	0.13	0.14
10ltr	0.5ind	0.85	0.88	0.50	0.22	0.05	0.15	0.16	0.12
Imax	0.5ind	0.87	0.88	0.50	0.24	0.05	0.10	0.14	0.18
L2			9686 686 686	15G3G5G5G5G5G5G5G5G5G5G5G5G5G5G5G5G5G5G5	6262626262626262626 6262626262626262626	eseseseses eseseseses eseseseses eseseseses			
ltr	1.0	0.98	0.86	0.51	0.23	0.04	0.09	0.13	0.17
10ltr	1.0	1.00	0.82	0.47	0.21	0.04	0.08	0.12	0.14
Imax	1.0	1.01	0.83	0.48	0.22	0.04	0.08	0.11	0.15
ltr	0.5ind	0.79	1.03	0.61	0.26	0.14	0.22	0.23	0.20
10ltr	0.5ind	1.23	0.69	0.35	0.10	0.15	0.21	0.24	0.21
Imax	0.5ind	1.20	0.67	0.32	0.06	0.18	0.24	0.28	0.26
L3				7059 950 951	63636363636363636363636363636363636363	ESTES GSTESTES GSTESTES GS 25 GS GSTEST GSTESTES GSTESTES 5 CG SGSTESTES GSTESTES 5 CG SGSTESTES 5 CG	SGSGSGSGSGS SGSGSGSGSGS SGSGSGSGSGS SG		
ltr	1.0	1.29	0.87	0.50	0.24	0.05	0.10	0.12	0.16
10ltr	1.0	1.27	0.85	0.48	0.22	0.04	0.09	0.11	0.15
Imax	1.0	1.27	0.84	0.48	0.22	0.05	0.09	0.12	0.16
ltr	0.5ind	2.02	0.97	0.56	0.27	0.09	0.13	0.13	0.20
10ltr	0.5ind	1.67	0.83	0.47	0.21	0.06	0.08	0.11	0.16
lmax	0.5ind	1.66	0.83	0.47	0.21	0.04	0.09	0.11	0.15



0120/SGS0142

Issue Number: 1

Dated:21st January 2022

5. Annex of Variants

Product Variant Identification Details:

Type Designation	Description of meter
SDM 630MCT	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated (Terminal 7 and 8 used as power output for next meter in daisy connection)
SDM 630MCT 2T	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated (Terminal 7 and 8 is used as signal input for two tariff shifting)
SDM 630MCT Mbus	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated, Mbus communication
SDM630MCT-E	0.25-5(6)A - Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated
SDM630MCT-DI	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated. Digital inputs
SDM630MCT-2T-Mbus	0.25-5(6)A – Polyphase, Active Import/Export kWh, Multifunction, Transformer Operated, Mbus communication (Terminal 7 and 8 is used as signal input for two tariff shifting)
SDM630MCT-MT	0.25-5(6)A - Polyphase, Active Import/Export kWh, Multifunction, Multi-tariff, Transformer Operated, Modbus communication
SDM630MCT-LoRa	0.25-5(6)A – Polyphase, Single tariff, total active energy, resettable active energy, import active energy, export active energy, total reactive energy, import reactive energy, export reactive energy, active power, reactive power, voltage, current, frequency, power factor, power demand, LoRa communication.

Modifications to the meter(s) described according to approval No.0120/SGS0142 must be notified to the issuing body to confirm the meter(s) continuing compliance to the relevant pattern approval standard(s).



0120/SGS0142

Issue Number: 1

Dated:21st January 2022

6. Document Revision History

Issue	Date	Comments
1	10/03/2014	Initial Issue
2	11/10/2016	SDM630MC -2T and SDM630MCT-Mbus added to approval
3	21/12/2018	SDM630MCT-E added to approval
4	08/08/2019	SDM630CT-DI, SDM630MCT-2T-Mbus, SDM630MCT-MT added to approval
5	31/10/2019	Meter accuracy improved to meet Class C limits
6	14/09/2020	SDM630MCT-LoRa added to approval
1	18/01/2022	Issue 1 for SGS Fimko NB 0598 The original approval certificate issued 10/03/2014 The modifications listed above were made prior to the transfer to SGS Fimko Temperature range extended to -40°C - +70°C

This document is issued by the Company subject to its General Conditions for Certification Services, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx.

Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 28 days only.

END OF CERTIFICATE